



NOTE:

1. REFER TO HYDRO ONE BRAMPTON TS-1 SPECIFICATION SECTION 6 OR TO HYDRO ONE BRAMPTON TECHNICAL SERVICES DEPARTMENT FOR COMPLETE REQUIREMENTS .
2. SWITCHES AND METER MOUNTING DEVICES ARE TO BE IDENTIFIED AS TO CUSTOMER/LOAD BEING METERED.
3. A METER ROOM IS TO BE EQUIPPED WITH A 120V DUPLEX RECEPTACLE AND BE ILLUMINATED WITH A MINIMUM OF ONE 100 WATT INCANDESCENT CEILING MOUNTED FIXTURE FOR EVERY 9.3 SQ. M OF CEILING. FIXTURES ARE TO BE MOUNTED AT A MAXIMUM HEIGHT OF 2.4m ABOVE FLOOR.
4. FOR METER CABINET SIZES CONSULT TECHNICAL SERVICES DEPARTMENT.

CHECKED: *W. Tran*

APPROVED: *Bruno*

ORIGINAL ISSUE: JULY 29, 1986

GENERAL SERVICE
METER CABINET & METER
SOCKET INSTALLATION