



NOTE:

1. DOORS SHALL HAVE A VON DUPRIN 22 SERIES EXIT DEVICES OR EQUIVALENT.
2. DOORS TO OPEN OUTWARD.
3. DOOR OPENING FACING DRIVEWAYS SHOULD HAVE BOLLARDS FOR PROTECTION.
4. DOORS INSTALLED ABOVE GRADE MUST HAVE LANDING AND HANDRAIL AS PER BUILDING CODE.
5. DEADBOLT ASSEMBLY NOT REQUIRED FOR NEW DOOR INSTALLATIONS.
6. EXISTING DOOR UPGRADES MUST BE COMPLIANT WITH THE NEW DOOR SPECIFICATIONS.
ANY UNUSED HOLES TO BE PERMANENTLY SEALED.
7. THE DOOR LOCK MUST BE A RIM CYLINDER. OTHER STYLES OF CYLINDERS WILL BE
BE MODIFIED BY HYDRO ONE BRAMPTON LOCKSMITH AT CUSTOMER'S EXPENSE.
8. DOOR MUST HAVE PULL HANDLE, VON DUPRIN 210NL/230NL OR EQUIVALENT.
9. DOOR SHOULD HAVE DOOR CLOSER AS PER BUILDING CODE REQUIREMENTS.
10. ANY DOOR KEY MODIFICATIONS WILL BE AT CUSTOMER EXPENSE.
11. ANY DOOR/HARDWARE MODIFICATIONS MUST BE APPROVED BY HYDRO ONE BRAMPTON.
12. SEE STD. 35-43 AND STD. 35-44 FOR INSTALLATION OF WARNING LABELS.

CHECKED: *W. Ron*

APPROVED: *Dennis*

ORIGINAL ISSUE: JANUARY 29, 2007

ELECTRICAL ROOM EXIT
DOOR LATCHING HARDWARE