



NOTE :

1. ALL DIMENSIONS ARE SHOWN IN MILLIMETRES.
2. FOUNDATION TO BE PRECAST CONCRETE PAD. MANUFACTURER WILL DELIVER THE UNIT TO THE SITE.
3. COMPLETE THE EXCAVATION AND PROVIDE BEDDING CONSISTING OF MIN. 150 mm LAYER OF THOROUGHLY COMPACTED \diamond " CLEAN CRUSHED STONE.
4. PLACE BACKFILL CONSISTING OF CLEAN EARTH, SAND, OR PEA GRAVEL IN THOROUGHLY COMPACTED LAYERS.
5. PAD LOCATION TO BE KEPT CLEAR OF OBSTRUCTIONS FOR ACCESS BY HYDRO ONE BRAMPTON PERSONNEL AND EQUIPMENT.
6. INSTALL 4-10' GROUND RODS AND MIN. 2/0 STRANDED COPPER GROUND WIRE. REFER TO STD. 41-10.

CHECKED: *W. Ron*

APPROVED: *O. H. H.*

ORIGINAL ISSUE: SEPT. 23, 1991

INSTALLATION OF PRECAST
FOUNDATION FOR
1 PH PADMOUNT TRANSFORMER