



NOTE:

1. REFER TO HYDRO ONE BRAMPTON SPECIFICATIONS FOR INSTALLATION OF CABLE SPLICING MANHOLE.
2. DUCT POSITION MAY VARY DEPENDING ON CABLE ROUTE.
3. FOR MANHOLE DETAILS SEE STD. 37-360.
4. REFER TO STD. 41-37 FOR MANHOLE EXTERNAL GROUNDING DETAIL.
5. 125mm PIPE TO BE CAPPED AT STREETLINE FOR FUTURE EXTENSION.
6. EXTENSION OF 125mm PVC PIPE AND INSTALLATION OF P-TRAP TO BE COMPLETED BY APPROVED HYDRO ONE BRAMPTON CONTRACTOR.

REFERENCE	SECTION
MATERIALS	15
GROUNDING	41

CHECKED: *W. Ron*

APPROVED: *O. H. H.*

ORIGINAL ISSUE: OCTOBER 5, 1995

MANHOLE CABLE RACKING AND
INTERNAL GROUNDING DETAIL