



NOTE:

1. LEAVE 3 METRES OF 2/0 CU WIRE INSIDE OF MANHOLE.
2. FOR MANHOLE DETAILS SEE STD. 37-360.

REFERENCE

MATERIALS
UNDERGROUND

SECTION

15
37

CHECKED: *W. Ron*

APPROVED: *O. Hill*

ORIGINAL ISSUE: FEBRUARY 02, 2001

MANHOLE EXTERNAL
GROUNDING DETAIL